



March 29, 2017

LEAP Academy University Charter School
 130 North Broadway
 Camden, NJ 08102

Dear LEAP Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, LEAP Academy has tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, LEAP Academy will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within LEAP Academy. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 56 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action LEAP Academy has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Lower School kitchen prep sink ID #SLE-00-B-11-FP-P	39.0	Disconnected outlet. Faucet and supply lines are being replaced including water filtration unit.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause

STEM Elementary School Campus
 639 Cooper Street
 Camden, NJ 08102
 Main #: 856-614-5600
 Fax: 856-614-5601

STEM Upper Elementary School Campus
 549 Cooper Street
 Camden, NJ 08102
 Main #: 856-614-0400
 Fax: 856-342-7190

STEM Intermediate Campus
 532 Cooper Street
 Camden, NJ 08102
 Main #: 856-614-3292/3290
 Fax: 856-541-0526

Dr. Gloria Bonilla-Santiago
 Building STEAM High School
 Campus
 130 North Broadway
 Camden, NJ 08102
 Main#: 856-614-5640
 Fax: 856-338-1036



brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.leapacademycharter.org. For more information about water quality in our schools, contact Ken Verrill at the Business Office, 856-614-5096.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in blue ink, appearing to read "Manuel Delgado", is written over a horizontal line.

Manuel Delgado
Lead Person

STEM Elementary School Campus
639 Cooper Street
Camden, NJ 08102
Main #: 856-614-5600
Fax: 856-614-5601

STEM Upper Elementary School Campus
549 Cooper Street
Camden, NJ 08102
Main #: 856-614-0400
Fax: 856-342-7190

STEM Intermediate Campus
532 Cooper Street
Camden, NJ 08102
Main #: 856-614-3292/3290
Fax: 856-541-0526

Dr. Gloria Bonilla-Santiago
Building STEAM High School
Campus
130 North Broadway
Camden, NJ 08102
Main#: 856-614-5640
Fax: 856-338-1036



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

3/28/2017

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Leap Lower Elementary Campus - SLE / 639 Cooper Street,
Camden, NJ 08102**

The reference number for these samples is EMSL Order #011701853. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 03/28/2017 15:16:19 Replaces initial report from 03/27/2017 13:58:34 Project description corrected at the client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701853
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Leap Lower Elementary Campus - SLE / 639 Cooper Street, Camden, NJ 08102

Analytical Results

Client Sample Description		FB	Collected:	3/11/2017	Lab ID:	0001			
		Field-Blank							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		1	Collected:	3/11/2017	Lab ID:	0002			
		SLE-00-B-11-FP-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	39.0	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		2	Collected:	3/11/2017	Lab ID:	0003			
		SLE-00-H-STORAGE-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		3	Collected:	3/11/2017	Lab ID:	0004			
		SLE-00-H-STORAGE-WC2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		4	Collected:	3/11/2017	Lab ID:	0005			
		SLE-01-H-109-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		5	Collected:	3/11/2017	Lab ID:	0006			
		SLE-01-H-109-WC2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		6	Collected:	3/11/2017	Lab ID:	0007			
		SLE-02-H-211-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		7	Collected:	3/11/2017	Lab ID:	0008			
		SLE-02-H-211-WC2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701853
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Leap Lower Elementary Campus - SLE / 639 Cooper Street, Camden, NJ 08102

Analytical Results

Client Sample Description 7 *Collected:* 3/11/2017 *Lab ID:* 0008
 SLE-02-H-211-WC2-P

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 8 *Collected:* 3/11/2017 *Lab ID:* 0009
 SLE-03-H-301-WC1-P

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 9 *Collected:* 3/11/2017 *Lab ID:* 0010
 SLE-03-H-301-WC2-P

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Jessica Perrini
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691**

3/28/2017

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Leap Stem Upper Elementary - SUE / 549 Cooper Street, Camden,
NJ 08102**

The reference number for these samples is EMSL Order #011701859. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 03/28/2017 15:24:33 Replaces initial report from 03/27/2017 12:21:53 Project description corrected at the client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701859
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Leap Stem Upper Elementary - SUE / 549 Cooper Street, Camden, NJ 08102

Analytical Results

Client Sample Description		FB	Collected:	3/11/2017	Lab ID:	0001			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		1	Collected:	3/11/2017	Lab ID:	0002			
		SUE-01-BASE-H819-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		2	Collected:	3/11/2017	Lab ID:	0003			
		SUE-01-BASE-H819-WC2							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		3	Collected:	3/11/2017	Lab ID:	0004			
		SUE-01-B-KIT-B02-IM-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		4	Collected:	3/11/2017	Lab ID:	0005			
		SUE-01-B-KIT-B02-FP1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	1.52	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		5	Collected:	3/11/2017	Lab ID:	0006			
		SUE-01-B-KIT-B02-FP2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	1.04	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		6	Collected:	3/11/2017	Lab ID:	0007			
		SUE-01-B-KIT-B02-KT-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	2.54	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		7	Collected:	3/11/2017	Lab ID:	0008			
		SUE-01-1ST-J127-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701859
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Leap Stem Upper Elementary - SUE / 549 Cooper Street, Camden, NJ 08102

Analytical Results

Client Sample Description 7 **Collected:** 3/11/2017 **Lab ID:** 0008
 SUE-01-1ST-J127-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 8 **Collected:** 3/11/2017 **Lab ID:** 0009
 SUE-01-1ST-J127-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 9 **Collected:** 3/11/2017 **Lab ID:** 0010
 SUE-01-2ND-H208-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 10 **Collected:** 3/11/2017 **Lab ID:** 0011
 SUE-01-2ND-H208-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 11 **Collected:** 3/11/2017 **Lab ID:** 0012
 SUE-01-3RD-M301-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 12 **Collected:** 3/11/2017 **Lab ID:** 0013
 SUE-01-3RD-M301-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Jessica Perrini
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691**

3/28/2017

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Stem Intermediate Campus- SIC / 532 Cooper Street, Camden, NJ
08102**

The reference number for these samples is EMSL Order #011701851. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 03/28/2017 15:04:40 Replaces initial report from 03/27/2017 16:49:03 Project description corrected at the client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701851
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: **Stem Intermediate Campus- SIC / 532 Cooper Street, Camden, NJ 08102**

Analytical Results

Client Sample Description		FB	Collected:	3/11/2017	Lab ID:	0001			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		2	Collected:	3/11/2017	Lab ID:	0002			
		SIC-01-KIT-122-IM-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		1	Collected:	3/11/2017	Lab ID:	0003			
		SIC-01-KIT-122-FP-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		3	Collected:	3/11/2017	Lab ID:	0004			
		SIC-01-MAIN-H-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		4	Collected:	3/11/2017	Lab ID:	0005			
		SIC-01-MAIN-H-WC2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		5	Collected:	3/11/2017	Lab ID:	0006			
		SIC-01-H-105-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/27/2017	EG	3/27/2017	EG	
Client Sample Description		6	Collected:	3/11/2017	Lab ID:	0007			
		SIC-01-H-105-WC2-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		7	Collected:	3/11/2017	Lab ID:	0008			
		SIC-02-H-222-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701851
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: **Stem Intermediate Campus- SIC / 532 Cooper Street, Camden, NJ 08102**

Analytical Results

Client Sample Description 7 **Collected:** 3/11/2017 **Lab ID:** 0008
 SIC-02-H-222-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 8 **Collected:** 3/11/2017 **Lab ID:** 0009
 SIC-02-H-222-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 9 **Collected:** 3/11/2017 **Lab ID:** 0010
 SIC-02-H-224-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 10 **Collected:** 3/11/2017 **Lab ID:** 0011
 SIC-02-H-224-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 11 **Collected:** 3/11/2017 **Lab ID:** 0012
 SIC-02-H-322-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 12 **Collected:** 3/11/2017 **Lab ID:** 0013
 SIC-02-H-322-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 13 **Collected:** 3/11/2017 **Lab ID:** 0014
 SIC-02-H-320-WC1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Client Sample Description 14 **Collected:** 3/11/2017 **Lab ID:** 0015
 SIC-02-H-320-WC2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701851
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Stem Intermediate Campus- SIC / 532 Cooper Street, Camden, NJ 08102

Analytical Results

Client Sample Description 14 *Collected:* 3/11/2017 *Lab ID:* 0015
 SIC-02-H-320-WC2-P

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Jessica Perrini
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691**

3/28/2017

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Stem High School Campus- SHS / 130 N Broadway, Camden,
NJ 08102**

The reference number for these samples is EMSL Order #011701857. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 03/28/2017 15:22:54 Replaces initial report from 03/27/2017 12:14:49 Project description corrected at the client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701857
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: **Stem High School Campus- SHS / 130 N Broadway, Camden, NJ 08102**

Analytical Results

Client Sample Description		FB	Collected:	3/11/2017	Lab ID:	0001			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		18	Collected:	3/11/2017	Lab ID:	0002			
		SHS-12-H-1202-WC1-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		17	Collected:	3/11/2017	Lab ID:	0003			
		SHS-12-H-1202-WC2-p							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		16	Collected:	3/11/2017	Lab ID:	0004			
		SHS-11-H-1102-WC-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		15	Collected:	3/11/2017	Lab ID:	0005			
		SHS-10-H-1002-WC-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		14	Collected:	3/11/2017	Lab ID:	0006			
		SHS-09-H-902-WC-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		13	Collected:	3/11/2017	Lab ID:	0007			
		SHS-08-H-802-WC-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG	
Client Sample Description		12	Collected:	3/11/2017	Lab ID:	0008			
		SHS-07-H-702-WC-P							
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701857
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: Stem High School Campus- SHS / 130 N Broadway, Camden, NJ 08102

Analytical Results

Client Sample Description 12 **Collected:** 3/11/2017 **Lab ID:** 0008
 SHS-07-H-702-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 11 **Collected:** 3/11/2017 **Lab ID:** 0009
 SHS-06-H-602-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 10 **Collected:** 3/11/2017 **Lab ID:** 0010
 SHS-05-H-502-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 9 **Collected:** 3/11/2017 **Lab ID:** 0011
 SHS-04-H-402-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 8 **Collected:** 3/11/2017 **Lab ID:** 0012
 SHS-03-H-302-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 7 **Collected:** 3/11/2017 **Lab ID:** 0013
 SHS-02-H-202-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 6 **Collected:** 3/11/2017 **Lab ID:** 0014
 SHS-01-H-RESTROOM-WC-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 5 **Collected:** 3/11/2017 **Lab ID:** 0015
 SHS-01-RM-104-IM-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701857
 CustomerID: PARS51
 CustomerPO:
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 03/13/17 9:00 AM

Project: **Stem High School Campus- SHS / 130 N Broadway, Camden, NJ 08102**

Analytical Results

Client Sample Description 5 **Collected:** 3/11/2017 **Lab ID:** 0015
 SHS-01-RM-104-IM-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 3 **Collected:** 3/11/2017 **Lab ID:** 0016
 SHS-01-KIT-KT-1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 4 **Collected:** 3/11/2017 **Lab ID:** 0017
 SHS-01-KIT-KT-2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.56	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 1 **Collected:** 3/11/2017 **Lab ID:** 0018
 SHS-01-KIT-FP-1-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Client Sample Description 2 **Collected:** 3/11/2017 **Lab ID:** 0019
 SHS-01-KIT-FP-2-P

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.88	1.00	µg/L	3/13/2017	AE	3/15/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)